

Project Name	Stirling Care Home
Contract Ref	JOB-2026-0035
To (Client)	Willmott Dixon
Variation No.	VAR-002
Date of Issue	1st August 2026
From (Contractor)	—

NOTIFICATION

We hereby submit the following variation to the contract works for your instruction and agreement:

Variation	Defective structural deck requiring replacement
Instructed By	contractor
Instruction / Clause Ref	Clause 5.1
Status	Agreed

SCOPE OF THE VARIATION

Significant corrosion found to metal decking beyond the allowance in the contract bill. Additional deck replacement instructed to provide a sound substrate.

Claimed Value	£4,550.00
Agreed Value	£3,913.00

Signed: James (for the Contractor)

Client Signature: